



Cooper Union
Solar Decathlon Semifinal Presentation




Freedom Village for Barrier Free Living




NYC Housing and Climate Crises

- Buildings account for 70% of GHG emissions in New York
- 60,000 New Yorkers in homeless shelters every night
- Individuals with disabilities & domestic violence victims disproportionately affected

NYC GHG Emissions (%)



Poverty Rate in Manhattan





Design Partners and Site

barrier free living



JCJ ARCHITECTURE

Mission: Support individuals to live dignified lives free of all forms of abuse and bias

Designing new facility with transitional housing, administration offices, community spaces and terrace


270 East 2nd Street: Freedom Village Project



Redesign for climate performance and breaking the perception of affordable housing project so victims of domestic violence with disabilities can rebuild their lives

Zoning - R8A

Medium Density Contextual
Residence District

- Max Building Height of 120 ft
- FAR of 6.02
- Easily accessible to subway and public transportation





Residential Bulk

Outdoor Terrace

Communal Program





Common Areas

Communal Space

BFL Programming

Ground Floor Level






Communal Space

Outdoor Terrace

Rooftop Plan






Studio

2B1B



1B1B

Typical Residential Floorplan




Occupant Experience: Spatial Daylight Autonomy (sDA)

- sDA metric: Percent of total floor area which receives >300 lux of daylight for 50% of the time from 8:00 to 18:00
- All residential levels receive around 13% sDA



Occupant Experience: Annual Sunlight Exposure (ASE)


- (ASE) determines areas of the building which will receive excessive glare during certain times of the year
- Only 9% of total floor area exposed to glare: qualifying for LEED Pass



ASE Legend




Solar Energy
Total Output:
97,900 – 139,000
kWh/year




Façade: 53 kW DC System
Output: 13,800 – 54,900 kWh/year


Canopy system for maneuverable space and fire department access



Roof: 60 kW DC System
Output: 84,100 kWh/year




<https://pvwatts.nrel.gov/pvwatts.php>




Solar Cost Analysis

- The upfront cost factoring in incentives is \$375,900
- Additional low-income housing incentives are distributed over a 10-year period
- The energy savings are ~\$23,000-32,000/year
- The solar array payback period is 10 - 11 years




Structural: Floor Plan and Superstructure

- Columns and Beams made of Recycled Steel and varied across the floors to reduce weight
- 6.87in CLT flooring in order to minimize carbon footprint (175E lumber)
- Stairwell cores will serve as shear walls (12 inch thick, 315E lumber)




Hybrid Structural Framing:
Steel Beams & Columns
CLT Shear Walls & Floor Slabs



Column Splice




CLT Floor Slab manufacturer




Finite Element Analysis:
Color coded members

Durability & Resilience

- Different wind directions and angles of attack, 130 MPH wind (ASCE 7-16)
- Active pumping and mat slab drainage
- Emergency power generation from battery backup



CFD Model for High Winds:
Wind pressure contours




Hurricane Sandy
Severity of flood

Friction Pile Foundation & Fireproofing

- Micro Pile Foundation
 - Deep bedrock (103ft)
 - Mechanical equipment mounted on second floor exterior walls
 - Steel members encased in fire resisting materials
 - 4 9-5/8" bored steel piles




Outdoor Heat Pumps




$$D = 4bf + 2d - 2tw$$

Fireproofing of steel frame





Micro Pile Foundation:
Side view



Micro Pile Foundation:
Top view

Roof - Steel Framing with Metal Deck

- Composite section minimizes future maintenance costs
- 3.5in concrete slab
- Accessible roof



Typical Roof Detail
Side view

VULCRAFT®

1.5VL / 1.5VLI COMPOSITE DECK

SECTION PROPERTIES

Deck Gauge	Design Thickness (in.)	Deck Weight (psf)	Section Properties					F _y (ksi)
			I _p (in ⁴ /ft)	S _p (in ³ /ft)	I _x (in ⁴ /ft)	S _x (in ³ /ft)	V _s (lbs/ft)	
22	0.0295	1.67	0.139	0.167	0.173	0.177	2626	50
20	0.0358	2.03	0.182	0.218	0.216	0.226	3171	50
19	0.0418	2.37	0.224	0.259	0.252	0.275	3685	50
18	0.0474	2.69	0.265	0.298	0.286	0.314	4160	50
16	0.0598	3.40	0.362	0.389	0.362	0.396	4156	40



(N = 9.35) NORMAL WEIGHT CONCRETE (145 PCF)

TOTAL SLAB DEPTH	DECK TYPE	SDI Max. Unshored Clear Span			Superimposed Live Load (PSF)														
		Clear Span			Clear Span (ft.-in.)														
		1 SPAN	2 SPAN	3 SPAN	5'-0	5'-6	6'-0	6'-6	7'-0	7'-6	8'-0	8'-6	9'-0	9'-6	10'-0	10'-6	11'-0	11'-6	12'-0
3.50 (t=2.00) 33 psf	1.5VL22	6'-4	7'-5	7'-6	314	279	250	206	186	169	154	141	130	120	111	100	87	76	67
	1.5VL20	7'-7	8'-10	9'-0	345	306	275	249	227	208	171	157	144	134	124	108	94	82	73
	1.5VL19	8'-1	9'-10	10'-0	372	330	296	268	244	224	207	171	157	146	134	116	101	88	78
	1.5VL18	8'-7	10'-6	10'-9	395	351	315	285	260	238	220	204	168	156	142	123	107	94	82
	1.5VL16	9'-5	10'-5	10'-10	397	353	316	286	261	239	221	205	190	156	145	135	119	104	92

Corrugated Steel Deck

Construction Cost Estimate

RSMMeans



\$21,309,571.48

Building Cost

NEW YORK, NY

Location

10

Stories (Ea.)

Yes

Basement

\$378.46

Cost per S.F.

56,306

Floor Area

10.00


Story Height

\$999,824.00


Additive Cost

The construction costs are estimated to be \$378/sq ft - \$460/sq ft


CO2 Emissions by Life Cycle Stage



CO2 Emissions by Resource Type



CO2 Emissions By Structural Element




Embodied Environmental Impact

LCA of Major Structural Elements and Material Justifications

Thermally Resistant, Airtight Envelope

- Above required insulation levels
 - Roof R-50 (> R-49)
 - Walls R-28 (> R-20)
 - Foundation R-38
- Triple pane windows
- Maximum of 0.6 ACPH at 50 Pa




Variable Refrigerant Flow (VRF) System


- Air-Source Heat Pumps (COP = 4)
- Compatible with PV panels and increasingly sustainable electric grid



TAR-FL32MA-E
Wireless MA
Wireless Remote Controller



kumo cloud®
App-based Controller



Ventilation: Fixed-Bed Regenerator



Ductless ventilation system



Supply fresh, filtered air




Heat exchanging effectiveness in the range of 80%-90%



Humidity recovery of about 20-30%



Standard sound pressure difference is 42 dB



Ventilation: Fixed-Bed Regenerator



Ductless ventilation system



Supply fresh, filtered air



Heat exchanging effectiveness in the range of 80%-90%



Humidity recovery of about 20-30%



Standard sound pressure difference is 42 dB




Fig. 23 Single-Core Fixed-Bed Regenerator

Ventilation: Fixed-Bed Regenerator



Ductless ventilation system



Supply fresh, filtered air



Heat exchanging effectiveness in the range of 80%-90%



Humidity recovery of about 20-30%



Standard sound pressure difference is 42 dB





Fig. 23 Single-Core Fixed-Bed Regenerator

Fixed-Bed Regenerator 1-node Well-Mixed Model

- Effectiveness decreases transiently
- Overall average effectiveness assumed to be 40%-50% (latent effectiveness 25%-35%)
- 70% heating and cooling savings compared to ASHRAE Baseline






Lighting, Appliances, and Fixtures

- ADA compliant
- Energy Star rated
- Tankless Electric water heaters
 - Capable of handling large variations in water demand
- Smart-home integration
- Accessible Controls, Dimmers, Occupancy/Vacancy Sensors,

Memoirs®
Comfort Height® Toilet
K-3986






Energy Modeling: OpenStudio EnergyPlus

Energy Model Results

EUI Comparison



Thermal Comfort:

- No more than 5% of hours in a year over 76°F or under 68°F

Energy and Carbon Footprint:

- 50% energy reduction without renewables
- 70% energy reduction with renewables
- ~11,000 kWh per resident (43% lower than US average)
- Total utility cost of \$4800 per month
- 75-89 $\frac{tCO_{2e}}{year}$ based on **current** emission coefficients
- Below 2034 NYC Local Law 97 carbon target and will be net zero by 2040

ACCESSIBILITY | AFFORDABILITY | SUSTAINABILITY



Our design integrates these themes to help our residents reestablish their lives and to create a renewable, green future for them and for us all.

Team Members

Ilias Proko (CE '22)

Kevin Dai (ME '22)

Kai Huang (ARCH '22)

L Naw La Seng (CE '22)

Aviv Kresch (ChE '22)


Lionel Gilliar-Schoenenberger (CE '23)

Sarah Coraizaca (ME '23)

Sophia Zhao (CE '24)

Matviy Zhachek (CE '25)

Grace Ee (BSE '25)



Faculty Advisors

Melody Baglione

Cosmas Tzavelis

David Wootton

Julian Palacio

Alumni Design Mentors

Nick Triano

Eric Ringold

Neil Muir

Manny Feris

Multifamily Division Design Challenge

barrier free living



Solar Decathlon




THE COOPER UNION



Freedom Village for Barrier Free Living

Appendices

Heat Transfer Model (supply air period)



$$\dot{Q} = C_{core} \frac{dT_{core}}{dt}$$

(1) Discharge of capacitor through a resistor

$$= \frac{T_{core} - \bar{T}}{R_{conv}}$$

(2) Ohm's Law (voltage ΔT , current \dot{Q} , resistance R_{conv})

$$= \dot{m}c_p(T_{out} - T_{in})$$

(3) Advective current source and sink

$$R_{conv} = \frac{1}{hA}$$

$$A = n_{tubes}\pi dL$$

Solve for \bar{T} and Apply Euler's Method

Equations (2) and (3) $\rightarrow \bar{T} = \frac{\dot{m}c_p T_{in}}{\dot{m}c_p + \frac{1}{R_{conv}}} + \frac{T_{core}}{R_{conv}\dot{m}c_p + 1}$

Equations (1) and (2) $\rightarrow \frac{dT_{core}}{dt} = \frac{T_{core} - \bar{T}}{R_{conv}C_{core}}$

Euler's Method $\rightarrow T_{core}^{(p+1)} = T_{core}^{(p)} + \left(\frac{dT_{core}}{dt}\right)^{(p)} \Delta t$

$$\rightarrow \bar{T}^{(p+1)} = \frac{\dot{m}c_p T_{in}}{\dot{m}c_p + \frac{1}{R_{conv}}} + \frac{T_{core}^{(p+1)}}{R_{conv}\dot{m}c_p + 1}$$

$$\rightarrow \frac{dT_{core}^{(p)}}{dt} = \frac{T_{core}^{(p)} - \bar{T}^{(p)}}{R_{conv}C_{core}}$$

$$\begin{aligned} \dot{Q} &= C_{core} \frac{dT_{core}}{dt} && \text{(1) Discharge of capacitor through a resistor} \\ &= \frac{T_{core} - \bar{T}}{R_{conv}} && \text{(2) Ohm's Law (voltage } \Delta T, \text{ current } \dot{Q}, \text{ resistance } R_{conv}) \\ &= \dot{m}c_p(\bar{T} - T_{in}) && \text{(3) Advective current source and sink} \end{aligned}$$

$$\begin{aligned} \tau &= R_{conv}C_{core} \\ \Delta t &= \frac{\tau}{10} \end{aligned}$$


Heat Transfer Model Inputs



INPUTS		
V_flow	0.005	m ³ /s
roh	1.204	kg/m ³
cp_air	1.005	kJ/kg-K
T_in	5	oC
T_room	20	oC
h	0.005	kW/m ² -K
d_tube	0.005	m
L	0.243	m
m_core	3	kg
cp_core	0.903	kJ/kg-K

DERIVED PARAMETERS		
m_dot	0.00602	m ³ /s
C_core	2.71	kJ/K
A_FBR	0.0206	m ²
A_tube	0.0000196	m ²
n_tubes	1050	
A	4.01	m ²
R	49.9	K/kW

Sample Structural Floor Plan



www.autodesk.com/revit

Cooper Union SD2022
Freedom Village

No.	Description	Date

Level 2-10 Structural Floor Plan

Project number	270 East 2nd Street	S102
Date	3/28/2022	
Drawn by	L. Seng	Scale 1" = 10'-0"
Checked by	I. Proko	

Structural Members and Efficiency

Table 1: Structural Steel Members and Associated Efficiencies

Structural Member	Weight (lb/ft)	Efficiency of Structural Member
W10X45	45	90%
W10X77	77	85%
W12X120	120	98%
W14X82	82	90%
W14X30	30	84%

CoveTool Radiation Gradient




Section	Radiation Exposure	Total kWh
Roof	100%	84,000
Top 25% of Façade	70%	4,125
Bottom 75% of Facade	10%	9,625
		97,750

Calculation

$55,000 \text{ kWh} * 10\% * 75\% \text{ area} = 4,125$

$55,000 \text{ kWh} * 70\% * 25\% \text{ area} = 9,625$



NYC LL97 Carbon Emissions Calculator

FIND BUILDING

DEMO



Building Inputs

Building Type [?](#) Area (SF)

1 R-2 (Residential) X

+ Add Building Type

Utility Inputs

Use Default Rates [?](#)

Electricity - kWh \$/kWh

Natural Gas - therms \$/therm

Steam - mLbs \$/mLb

Fuel Oil 2 - gal \$/gal

Fuel Oil 4 - gal \$/gal

Estimated Carbon Summary

89
tCO₂e/yr

0.0016
tCO₂/sf/yr


2035+
Threshold: 78 tCO₂e/yr
Est. Penalty: \$2,869/yr

2030-2034
Threshold: 226 tCO₂e/yr
Est. Penalty: \$0/yr

2024-2029
Threshold: 375 tCO₂e/yr
Est. Penalty: \$0/yr



Estimated Annual Cost Summary



Estimated Building Metrics

Cost
\$67,440
\$1/sf/yr

Energy
1.05M kBtu
19 kBtu/sf/yr



Carbon
89 tCO₂e
0.0016 tCO₂e/sf/yr

Electricity


What now? Visit [NYC Accelerator](#) for free, personalized advisory services to improve building energy efficiency and lower carbon emissions.

Calculator engine by AKF Group LLC



Zoning




Zoning



Mechanical Plans



Mechanical Plans



Outdoor Unit Heat Pump Schedules																			
Designation on Drawings	Location	Indoor Units Served	Manufacturer	Model #	Capacity		Fan		Refrigerant	Dimensions			Net Weight	Sound Pressure Levels (dB(A))	Indoor Unit		Operating Temperature Range		COP
					Cooling (BTUH)	Heating (BTUH)	Airflow Rate (CFM)	Motor Output (kW)		Height (In)	Width (In)	Depth (in)			Total Capacity	Quantity	Cooling	Heating	
VRF-1	Floor 2 West Wall	Floor 1 Offices and Conference Rooms (along outer perimeter)	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-2	Floor 2 West Wall	Floor 2 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-3	Floor 2 West Wall	Floor 3 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-4	Floor 2 West Wall	Floor 4 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-5	Floor 2 West Wall	Floor 5 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-6	Floor 2 East Wall	Floor 6 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-7	Floor 2 East Wall	Floor 7 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-8	Floor 2 East Wall	Floor 8 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-9	Floor 2 East Wall	Floor 9 Residential Spaces	TRANE/MITSUBISHI ELECTRIC	TUMYP 0361AK43(NA/BA)	36,000	42,000	3885	2.8	R410A	52 - 11/16	41 - 11/32	13	267	49/53	50 -130% of Outdoor Unit Capacity	P05-P36 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4
VRF-10	Floor 2 East Wall	Rooftop Common Areas	TRANE/MITSUBISHI ELECTRIC	TUMYP0481AK42(NA/BA)	48,000	54,000	3885	3.3	R410A	52 - 11/16	41 - 11/32	13	267	51/54	50 -130% of Outdoor Unit Capacity	P05-P54 / 1-12	5° to 115° F D.B.	-13° to +59° F W.B.	4

Heat Pump with DOAS

Designation on Drawings	Location	Location Served	Manufacturer	Model #	Fan				Refrigerant			
					Capacity (BTUH)	Outdoor Fan FL (Amps)	Fan HP	Fan Dia (In)	Dimensions H x W x D Crated (In)	Refrigerant R-410A	Liquid (High Pressure) (In)	Gas (Low Pressure) (In)
HP-1	First Floor Outdoors	Lobby, Office 3, Conference Room 2	TRANE/MITSUBISHI ELECTRIC	4TWR5018H1000A	18000	0.54	44573	19.1	30.1 x 30 x 26.7	6 lbs	3/8 Flare	3/4 Flare

Heat Recovery Ventilators Schedule

Designation on Drawings	Manufacturer	Model #	Efficiency	Flow Rate	Power Consumption (W)	Supply Voltage/Frequency	Humidity Recovery	Measuring Surface Sound Pressure Level (dB)	Standard Sound Pressure Difference D _{n,W,open}	Length	Core Hole Diameter
HRV	Lunos	LUNOS e2 HRV	90.6	18/ 31/ 38 m³/h	1,4/ 2,8/ 3,3	12V DC	20-30%	16,5/ 19,5/ 26	42 dB	243 mm	162 mm

Indoor Unit Schedules														
Designation on Drawings	Location	Manufacturer	Model #	Type	Capacity		Dimensions			Airflow Rate (CFM)	Air Filter	Refrigerant Pipe Dimensions		
					Cooling (BTUH)	Heating (BTUH)	Height (In)	Width (In)	Depth (in)			Liquid (High Pressure)	Gas (Low Pressure)	Sound Pressure Levels (dB(A))
FCU-1-1	Conference 1	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-2	Conference 3	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-3	Conference 4	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-4	Office 1	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-5	Office 2	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-6	Office 4	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-7	Office 5	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-8	Office 6	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1-9	Office 7	TRANE/MITSUBISHI ELECTRIC	TPKFYP006LM140A	Wall Mounted	6000	6700	11 - 25/32	30-7/16	9 - 11/32	141-155-173-191	PP Honeycomb	1/4 Flare	1/2 Flare	22-26-29-31
FCU-1	Studio 1	TRANE/MITSUBISHI ELECTRIC	TPKFYP004LM140A	Wall Mounted	4000	4500	11 - 25/32	30-7/16	9 - 11/32	117-124-134-148	PP Honeycomb	1/4 Flare	1/2 Flare	22-24-26-28
FCU-2	Studio 2	TRANE/MITSUBISHI ELECTRIC	TPKFYP004LM140A	Wall Mounted	4000	4500	11 - 25/32	30-7/16	9 - 11/32	117-124-134-148	PP Honeycomb	1/4 Flare	1/2 Flare	22-24-26-28
FCU-3	2b1b	TRANE/MITSUBISHI ELECTRIC	TPFFYP006CS140A	Floor Standing	6000	6700	24 - 13/16	41 - 11/32	8 - 11/16	194-229	Standard Filter	1/4 Flare	1/2 Flare	36-41
FCU-4	2b1b	TRANE/MITSUBISHI ELECTRIC	TPLFYP 008FM140A	Ceiling Cassette	8000	9000	8 - 3/16	22 - 7/16	22 - 71/6	230-265-280	PP Honeycomb	1/4 Flare	1/2 Flare	26-30-33
FCU-5	2b1b	TRANE/MITSUBISHI ELECTRIC	TPFFYP006CS140A	Floor Standing	6000	6700	24 - 13/16	41 - 11/32	8 - 11/16	194-229	Standard Filter	1/4 Flare	1/2 Flare	36-41
FCU-6	1b1b	TRANE/MITSUBISHI ELECTRIC	TPFFYP006CS140A	Floor Standing	6000	6700	24 - 13/16	41 - 11/32	8 - 11/16	194-229	Standard Filter	1/4 Flare	1/2 Flare	36-41
FCU-7	1b1b	TRANE/MITSUBISHI ELECTRIC	TPKFYP004LM140A	Wall Mounted	4000	4500	11 - 25/32	30-7/16	9 - 11/32	117-124-134-148	PP Honeycomb	1/4 Flare	1/2 Flare	22-24-26-28
FCU-8	Studio 3	TRANE/MITSUBISHI ELECTRIC	TPKFYP004LM140A	Wall Mounted	4000	4500	11 - 25/32	30-7/16	9 - 11/32	117-124-134-148	PP Honeycomb	1/4 Flare	1/2 Flare	22-24-26-28
FCU-9	Studio 4	TRANE/MITSUBISHI ELECTRIC	TPKFYP004LM140A	Wall Mounted	4000	4500	11 - 25/32	30-7/16	9 - 11/32	117-124-134-148	PP Honeycomb	1/4 Flare	1/2 Flare	22-24-26-28
FCU-10	Studio 5	TRANE/MITSUBISHI ELECTRIC	TPKFYP004LM140A	Wall Mounted	4000	4500	11 - 25/32	30-7/16	9 - 11/32	117-124-134-148	PP Honeycomb	1/4 Flare	1/2 Flare	22-24-26-28
FCU-11	1b1b	TRANE/MITSUBISHI ELECTRIC	TPKFYP004LM140A	Wall Mounted	4000	4500	11 - 25/32	30-7/16	9 - 11/32	117-124-134-148	PP Honeycomb	1/4 Flare	1/2 Flare	22-24-26-28
FCU-12	1b1b	TRANE/MITSUBISHI ELECTRIC	TPFFYP006CS140A	Floor Standing	6000	6700	24 - 13/16	41 - 11/32	8 - 11/16	194-229	Standard Filter	1/4 Flare	1/2 Flare	36-41
FCU-R-1	Rooftop Common Area	TRANE/MITSUBISHI ELECTRIC	TPCFYP030KM140B	Ceiling Suspended	30000	34000	9 - 1/16	63	16 - 3/4	703-777-883-989	PP Honeycomb	3/8 Flare	5/8 Flare	34-37-40-43
FCU-R-2	Rooftop Common Area	TRANE/MITSUBISHI ELECTRIC	TPCFYP030KM140B	Ceiling Suspended	30000	34000	9 - 1/16	63	16 - 3/4	703-777-883-989	PP Honeycomb	3/8 Flare	5/8 Flare	34-37-40-43